Technical requirements for electronic control gears for LED and fluorescent lumninaires (dimmable or non-dimmable) for operation on INOTEC central battery systems (CPS 220 / CPS FUSION) and emergency power supply systems (NEA)



- General requirements -

| Manufacturer: | Type / Description: | | |
|-------------------------------|---------------------|--|--|
| | Luminaire | | |
| | EVG: | | |
| | LED: | | |
| Project / Place / Project ID: | Specified by: | | |
| | Name: | | |
| | Company: | | |
| | Date: | | |

| | | | Date: | | | | |
|----|--|---|---|-----------------------|--|--|--|
| | Features | Techn. data / INOTEC requirements | Explanation | Fullfilled (Yes / No) | | | |
| 1 | Voltage range AC | 230V ± 10% | Voltage range in normal mains operation | | | | |
| 2 | Voltage range DC | 186V - 260V | Possible voltage range in emergency operation | | | | |
| 3 | Control gear suitable for "Joker-Voltage" ? | B2-rectification of the AC voltage (without smoothing) | Pulsating DC voltage | | | | |
| 4 | Control gear compatible with change- over time of the system? | Change-over time: 150 - 1000ms | Typical change-over time of INOTEC systems between mains- and battery operation | | | | |
| 5 | Starting behavior of the control gear in AC and DC operation | Stable current consumption within 1.6s | Necessary for individual lamp monitoring (SV). The nominal current of the control gear must be reached within this time if the lamp is intact or defective. | | | | |
| 6 | Control gear complies with the standard: (only for fluorescent lamps) | DIN EN 60929 | AC and/or DC-supplied electronic control gear for tubular fluorescent lamps - Performance requirements | | | | |
| 7 | Control gear complies with the standard: (only for fluorescent lamps) | DIN EN 61347-2-3 (incl. Attachment J) | Particular requirements for AC and/or DC supplied electronic control gear for fluorescent lamps | | | | |
| 8 | Control gear complies with the standard: (only for LED) | DIN EN 62384 | DC or AC supplied electronic control gear for LED modules - Performance requirements | | | | |
| 9 | Control gear complies with the standard: (only for LED) | DIN EN 61347-2-13 | Lamp control gear - Part 2-13: Particular requirements for DC or AC supplied electronic control gear for LED modules | | | | |
| 10 | Control gear complies with the standard: | DIN EN 55015 (Measurement on AC and DC) | Limits and methods of measurement of radio interference | | | | |
| 11 | Control gear complies with the standard: | DIN EN 61000-3-2 | Electromagnetic compatibility (EMC) - Part 3-2: Limits - Limits for harmonic current emissions (equipment input current \leq 16 A per phase) | | | | |
| 12 | Control gear complies with the standard: | DIN EN 61547 | Equipment for general lighting purposes — EMC immunity requirements | | | | |
| 13 | Control gear complies with the DALIstandards: DIN EN 62386-101 /-102 / -207 | | The control and status information for monitoring the luminaire is provided via DALI commands. The DALI commands must be 100% compatible. | | | | |

Note: VDE 0108 is not a standard for ECG, marking is not applicable

Technical requirements for electronic control gears for LED and fluorescent lumninaires (dimmable or non-dimmable) for operation on INOTEC central battery systems (CPS 220 / CPS FUSION) and emergency power supply systems (NEA)



| Ma | nufacturer: | Type / Description: | |
|-----|--|---|----------------------|
| | | Luminaire | |
| | | EVG: | |
| | | LED: | |
| Pro | ject / Place / Project ID: | Specified by: | |
| | | Name: | |
| | | Company: | |
| | | Date: | |
| | Factoria | Fundamentian | 84 |
| | Features | Explanation | Manufacturer spec. |
| 14 | Nominal current of the control gear with connected illuminant in AC- operation (230V) | Selection guide for the calculation of the max. number of luminairs per circuit | mA |
| 15 | Naminal aureant of the central good with connected illuminant in | Selection guide for the calculation of the necessary battery capacity and | mA (186V) |
| | Nominal current of the control gear with connected illuminant in DC- operation (186V / 216V / 240V) | selection guide for determination of the monitoring module to recognise a | mA (216V) |
| | , , , , , | normal working lamp correctly. | mA (240v) |
| | Nominal current of the control gear with connected illuminant | | mA (186V) |
| 16 | at set dimming level in DC-operation (186V / 216V / 240V) | Selection guide for determination of the monitoring module to recognise a normal working lamp correctly. | mA (216V) |
| | (for dimmable control gear) | , , , , , , , , , , , , , , , , , , , | mA (240V) |
| 17 | · | Selection guide for determination of the monitoring module to recognise a | mA (186V) |
| 1, | illuminant in DC- operation (186V and 240V) | lamp failure correctly. | mA (240V) |
| 18 | Current consumption of the control gear without or with defective illuminant in AC- operation (230V) | Selection guide for determination of the monitoring module to recognise a lamp failure correctly. | mA |
| 19 | Dimming level in emergency mode (DC or "Joker") (for dimmable control gear, if activated) | Important for the safety lighting design | % |
| 20 | DC detection completely deactivalable ? (for dimmable control gear) | To ensure correct operation, the control gear should not react to a change of the input voltage (DC or "Joker"). In this case, the INOTEC DALI module (DALI-SV module or FMD 230/DALI) controls the control gear. | |
| 21 | Max. inrush current of the control gear with connected illuminant in AC- operation (230V) | Important for determining the maximum permissible number of luminaires per circuit in order to take account of the maximum contact load capacity of the circuit changeover circuit or monitoring module. | A / μs |
| 22 | Use of DALI commands according to IEC 62386 part 102: - DPAC (level) - RECALL MAX LEVEL 0x05 - RECALL MIN LEVEL 0x06 - QUERY STATUS 0x90 - QUERY ACTUAL LEVEL 0xA0 - QUERY LAMP FAILURE 0x92 | Control and status information for monitoring the luminaires: - Direct setting of a dimming value - Set maximum level - Set minimum level - Requests status telegram - Requests current dimming value - Requests lamp failure status (after 2 / 2.5 / 3 seconds!) | |
| Lun | ninaires, which should work as emergency lighting, have to be in acco | ordance with DIN EN 60598-2-22. (Particular requirements - Luminaires for e | emergency lighting). |
| | | | |

For the correctness: Signature Place, Date Stand: Sep. 2019 2/2 $INOTEC_Requirements\ for\ control\ gears_all_V6$

| Manufacturer: | Product: | | |
|----------------------|------------------------------|------------|--|
| OSRAM GmbH | | | |
| Marcel-Breuer Str. 6 | OT FIT_18_220-240_350_D_CS_L | OSRAM GmbH | |
| D-80807 München | (AM45642) | | |
| | | | |

Table 1

| | | | | AC-o _i | peration | | | | Operation fault DC Dim level e.g. : | 15%) |
|-----------------------|----------------|--------------------------------|--------------------------------|--------------------------------|--------------------------------|-------------------------|-------------------------|-------------------------|--|--------|
| Values for load range | | 189VAC/50Hz Itrms_in (mA) | 230VAC/50Hz Itrms_in (mA) | 240VAC/50Hz Itrms in (mA) | 264VAC/50Hz Itrms_in (mA) | 186VDC Idc_in (mA) | 216VDC Idc_in (mA) | 240VDC Idc_in (mA) | 260VDC Idc_in (mA) | |
| Min. Load /mA | Uout= lout= | 24.4 V 99.8 mA | not supported (25.6) | 23,4 | 23,1 | 24,8 | 19,7 | 17,0 | 15,5 | 14,4 |
| | P= | 2.43 W | PF: 0.763 | PF: 0.709 | PF:0.672 | PF: 0.567 | PF: NA | PF: NA | PF: NA | PF: NA |
| Mid. Load /mA | Uout= lout= | 28.2 V 342.7 mA | not supported (64.1) | 54,0 | 52,6 | 50,7 | 63,7 | 54,4 | 49,2 | 45,4 |
| | P= | 9.7 W | PF:0.958 | PF: 0.934 | PF:0.917 | PF:0.863 | PF: NA | PF: NA | PF: NA | PF: NA |
| Max. Load /mA | Uout= lout= | 56.0 V 341.6 mA | not supported (117.4) | 97,2 | 93,1 | 85,5 | 117,5 | 100,9 | 90,5 | 84,0 |
| | P= | 19.1 W | PF:0.984 | PF: 0.969 | PF:0.967 | PF:0.954 | PF: NA | PF: NA | PF: NA | PF: NA |
| Short/Open Load | | | not supported (12) | 12,5 | 12,6 | 13,1 | 1,2 | 0,9 | 0,8 | 0,8 |
| | | | PF:0.091 | PF: 0.084 | PF:0.086 | PF:0.104 | PF: NA | PF: NA | PF: NA | PF: NA |

Remarks:

- 1.) This table shows the currents consumption of the driver at three different operating points (Pmax, Pmid, Pmin) for AC and DC operation.
- 2.) This table is intended for rough design desicions . It is not a replacement for individual functional measurments!