

Requirements for	dimmable DALI control gea	rs for fluorescent lamps and LED	Version 5			
Manufacturer: Type / description: DSRAM GmbH TOO 1 THE OF DATE OF DA						
Marcel-Breuer-Str. 6 D-80807 München	lünchen Date: 22.07.2022					
Features:	CEAG data:	Explanation:				
Control gear suitable for a DC voltage range:	186V - 260V DC (for Lead-Battery)	Possible voltage range of the battery in emergency mode. (Not for AT-S ⁺ Systems required)	Yes			
Control gear compatible with the switch-over time of the system?	Switch-over time: 180 ms - 450 ms	Typical switch-over time of CEAG systems between mains supply and emergency power supply	Yes			
Starting behavior of the control gear:	Stable current consumption after less than 1.6 sec. maximum.	A stable operation of the control gear after 1.6 seconds of start up is required for the right functionality of the individual monitoring. With max. 20 luminaires for one current circuit: Δ l in sum < 250 mA are allowed	Yes			
Control gear compatible with CEAG STAR-Technology:	Phase-cut telegram (PAT): max. 30 phases (half waves) with max. 60° phase-cuts	During the CEAG STAR switching process, up to 30 half- waves are cut at a maximum of 60°. The control gear must not exhibit any malfunctions such as switching off, flickering	Yes			
only for flourescent lamps: Control gear complies with the standard:	DIN EN 60929	AC and/or DC-supplied electronic control gear for tubular fluorescent lamps - Performance requirements	Not relevant			
only for flourescent lamps. Control gear complies with the standard:	DIN EN 61347-2-3 (incl. Attachment J)	Particular requirements for AC and/or DC supplied electronic control gear for fluorescent lamps	Not relevant			
only for LED: Control gear complies with the standard:	DIN EN 62384	DC. Or AC supplied electronic control gear for LED modules - Performance requirements	Yes			
only for LED: Control gear complies with the standard:	DIN EN 61347-2-13	Lamp controlgear — Part 2-13: Particular requirements for d. c. or a. c. supplied electronic controlgear for LED modules	Yes			
Fullfilled the standard:	DIN EN 55015 (Measurement on AC And DC)	Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment	Yes			
Fullfilled the standard:	DIN EN 61547	Equipment for general lighting purposes — EMC immunity requirements	Yes			
Fullfilled the DALI standards:	DIN EN 62386-101 /-102 / -207*	Control gear must have the DALI Logo*	Yes			
Note: VDE 0108 is not a standard for ECG, mar	king is not applicable					
Features:	CEAG-Data:	Explanation:	Manufacturer information:			
Important for function test! According to IEC 62386 Part 102 Support of : DALI command 145 (Query Control Gear) DALI command 146 (Query Lamp Failure)	According to IEC 62386 Part 102	To detect a lamp failure, the V-CG-SB.1 module send DALI command queries (145/146) to the DALI LED driver. These DALI commands are necessary to ensure the lamp failure detection, and must be support by the control gear.	Yes			
Important for DC operation: DALI light level	In case of locked DALI light level in DC operation (EOF=Emergency Output Level),	In DC-emergency case the DALI-Light Level is locked to prevent unwanted changes of the luminous flux.	Locked			
Important for lighting design: If DALI-Light level is locked, the value of the preset DC-Lightlevel (in %) is required	the V-CG-SB.1 can not change the light level!	Pre-set DC-Light Level e.g. 15% (DALI-value 185 for logarithmic dimming curve)	15%			
Important for the planning - Important for the contact load SKU: Max. inrush current each converter/luminaire in AC-operation:	mortant for the planning - Max. no. Of luminiares per circuit Max. permitted inrush current per circuit: SKU 2 x 3A (CG) => 120 A SKU 1 x 6A (CG) => 180 A SKU 4 x 1,5A CG-S => 60 A SKU 2 x 3A CG-S => 250 A The declaration of the inrush current of the possible luminaires on one circuit, to conside					
		g, must be according to the standard DIN EN 60598-2-22 uminalres for emergency lighting)				

*Control of V-CG-SB.1 to the DALI LED driver is 100% done via DALI-commands according to IEC 62386-101 /-102 so the DALI LED driver must sign with the DALI logo

Max. 1 DALI- Driver to wire with 1 V-CG-SB.1

In use of manifold ballasts, the different lamp failure detection of the manufacturer must be consider! Some devices don't detect a failure if one lamp is defect.

06.March.2021

Manufacturer: OSRAM GmbH	Product:	
Marcel-Breuer Str. 6 D-80807 München	Oti 160/220-240/24 1CH G3 4062172274388	OSRAM GmbH

Table 1

			AC-operation					DC-Operation (For DALI Devices @ default DC Dim level e.g. 15%)				
Values for load ran	nge		189VAC/50Hz itrms_in (mA)	230VAC/50Hz Itrms_in (mA)	240VAC/50Hz ltrms_in (mA)	264VAC/50Hz ltrms_in (mA)	AC Dali level	186VDC Itrms_in (mA)	216VDC ltrms_in (mA)	240VDC ltrms_in (mA)	260VDC ltrms_in (mA)	DC Dali Level
Min. Load /mA	P_out=	15 W	not supported (128)	120	121	120	170	108	91	82	76	170
Mid. Load /mA	P_out=	77 W	not supported (450)	371	357	332	229	455	390	349	323	229
Max. Load /mA	P_out=	152 W	not supported (919)	718	693	676	254	899	768	688	634	254
ihort/Open Load			not supported (62)	70	72	77		20	20	19	18	

Remarks:

1.) This table shows the currents consumption of the driver at three different operating points (Pmax, Pmid, Pmin) for AC and DC operation.

2.) This table is intended for rough design desicions . It is not a replacement for individual functional measurments!

MICHIRLIZ MIZHEGAZZI

An.