



Fair
Trading

File Ref: CS10925N
Contact: Admin Clerk
Telephone: 02 9895 0722

Mr Darren Miruzzi
Osram Australia Pty Ltd
Level 6 & 7, 91 Phillip Street
PARRAMATTA NSW 2150

Dear Sir/Madam

CERTIFICATE OF SUITABILITY: CS10925N AND VARIATION/S

Power Supply (Build-in)

Please find enclosed a Certificate of Suitability and addendum as sought by your application.

Articles of the approved type may be marked with the mark (or alternate approval mark) shown on the Certificate.

THE APPROVAL EXPIRES ON THE DATE SHOWN ON THE CERTIFICATE unless it is renewed, extended, suspended or cancelled.

Yours faithfully

For Secretary, Department of Customer Service



**Fair
Trading**

Certificate of Suitability Non-Declared Article

Certificate Number: **CS10925N**

This is to certify that the article specified below is accepted by NSW FAIR TRADING as suitable for connection to public electricity supply in NEW SOUTH WALES in accordance with the provisions of AS/NZS 3000 and subject to the conditions stated.

Issued to:	Osram Australia Pty Ltd
Article:	LED Driver (Constant current, SELV, LED control gear for use in luminaires of construction class II)
Trade Name or Mark:	'OSRAM'
Ratings:	Volts: 220-240V ~ Amperes: Watts: 40W Hertz: 50/60 Hz Other Name Plate Particulars: I rated: 500-1050mA. P rated: 40W U rated: 20-50V, tc: 85°C NFC, DALI 2
Type Reference Code:	OTi DALI 40/220-240V/1A0 NFC S
Examined for Compliance With:	AS 61347.2.13: 2018
Nominated Marking:	CS10925N or approved alternate mark.
Date of Approval:	07/04/2020
Approval Expires:	07/04/2025 unless suspended, cancelled, renewed or extended.

Conditions:

1. This certification will be withdrawn automatically if an article of this type is declared pursuant to section 12 (2) of the Gas and Electricity (Consumer Safety) Act, 2017.
2. This certificate is issued subject to the article and approved variations being maintained at the standard of the article examined at the time of approval.



On behalf of the Secretary, Department of Customer Service

For current information regarding currency of certificate, refer to the Fair Trading Website



Fair
Trading

Ref: CS10925/1

ADDENDUM TO CERTIFICATE OF SUITABILITY: CS10925N
Particulars of Modification(s)

The addition of the following Model Nos:-

- (a) Model No. OTi DALI 20/220-240/500 NFC S being similar to original Model No. OTi DALI 40/220-240/1A0 NFC S, except P rated: 20W, I rated: 200-500mA, TC: 75°C.
- (b) Model No. OTi DALI 30/220-240/700 NFC S being similar to original Model No. OTi DALI 40/220-240/1A0 NFC S, except P rated: 30W, I rated: 350-700mA, TC: 75°C.

This certificate will expire on 07/04/2025

Approved: 8 April 2020

For Secretary, Department of Customer Service