

File Ref: NSW27964/2 Contact: Admin Clerk Telephone: 02 9895 0722

Mr Darren Miruzzi Osram Pty Ltd Level 7, 91 Phillip Street PARRAMATTA NSW 2150

Dear Sir/Madam

MODIFICATION TO CERTIFICATE OF APPROVAL: NSW27964

Power Supply or Charger

Please find enclosed an addendum to the certificate as sought in your application.

Yours faithfully,

8 September 2021

Email: energyapprovals@customerservice.nsw.gov.au

Website: www.fairtrading.nsw.gov.au

For Secretary, Department of Customer Service

Columnal

Ref: NSW27964/2



ADDENDUM TO CERTIFICATE OF APPROVAL: NSW27964 Particulars of Modification(s)

Addition of the following models of built-in, dipswitch programmable constant current, Class I, SELV LED drivers -

a) EM FIT 18/220-240/350 CS L -Ta: 50 Degree C, Tc: 65 Degree C, In: 0.082 / 0.95 / 0.11 / 0.125A, Irated: 200 / 250 / 300 / 350mA, Prated: 10.2 / 12.8 / 15.3 / 17.9W,

Urated: 27 - 51Vdc.

b) EM FIT 40/220-240/800 CS L -Ta: 50 Degree C, Tc: 75 Degree C, In: 0.175 / 0.2 / 0.24 / 0.28A, Irated: 500 / 600 / 700 / 800mA, Prated: 25.5 / 30.6 / 35.7 / 40.8W,

Urated: 27 - 51Vdc.

c) EM FIT 60/220-240/1A2 CS L -Ta: 50 Degree C, Tc: 75 Degree C, In: 0.27 / 0.33 / 0.34 / 0.37A,

Irated: 900 / 1050 / 1100 / 1200mA,

Prated: 45.9 / 53.6 / 56.1 / 61.2W,

Urated: 27 - 51Vdc.

8 September 2021

Electrical & Gas Approvals, NSW Fair Trading, PO Box 972, Parramatta NSW 2124 02 9895 0722

Chuntul

Email: energyapprovals@customerservice.nsw.gov.au

Website: www.fairtrading.nsw.gov.au





d) EM FIT 75/220-240/1A6 CS L -Ta: 50 Degree C, Tc: 75 Degree C,

In: 0.39 / 0.42 / 0.45 / 0.48A,

Irated: 1300 / 1400 / 1500 / 1600mA, Prated: 66.3 / 71.4 / 76.5 / 81.6W,

Urated: 27 - 51Vdc.

This certificate will expire on 14/06/2023

Approved pursuant to Clause 15 (1) of the Gas and Electricity (Consumer Safety) Regulation 2018:

8 September 2021

For Secretary, Department of Customer Service

Email: energyapprovals@customerservice.nsw.gov.au

Website: www.fairtrading.nsw.gov.au