

File Ref: NSW27963/2 Contact: Admin Clerk Telephone: 02 9895 0722

Mr Darren Miruzzi Osram Pty Ltd Level 7, 91 Phillip Street PARRAMATTA NSW 2150

Dear Sir/Madam

MODIFICATION TO CERTIFICATE OF APPROVAL: NSW27963

Power Supply or Charger

Please find enclosed an addendum to the certificate as sought in your application.

Yours faithfully,

8 September 2021

Email: energyapprovals@customerservice.nsw.gov.au

Website: www.fairtrading.nsw.gov.au

For Secretary, Department of Customer Service

Clustul

Ref: NSW27963/2



ADDENDUM TO CERTIFICATE OF APPROVAL: NSW27963 Particulars of Modification(s)

Addition of the following models of built-in, dipswitch programmable constant current, Class I LED drivers -

a) EM FIT 18/220-240/350 D CS L - Ta: 50 Degree C, Tc: 60 Degree C,

In: 0.085 / 0.1 / 0.11 / 0.13A, Irated: 200 / 250 / 300 / 350mA, Prated: 10.8 / 13.5 / 16.2 / 18.9W,

Urated: 25 - 54Vdc.

b) EM FIT 40/220-240/350 D CS L - Ta: 60 Degree C, Tc: 75 Degree C,

In: 0.15 / 0.19 / 0.22 / 0.25A, Irated: 200 / 250 / 300 / 350mA, Prated: 24 / 30 / 36 / 42W,

Urated: 40 - 120Vdc.

c) EM FIT 60/220-240/350 D CS L Ta: 50 Degree C, Tc: 75 Degree C, -

In: 0.24 / 0.29 / 0.34 / 0.39A, Irated: 200 / 250 / 300 / 350mA, Prated: 35 / 43.8 / 52.5 / 61.3W,

Urated: 90 -175Vdc.

d) EM FIT 75/220-240/550 D CS L - Ta: 50 Degree C, Tc: 75 Degree C,

In: 0.47A,

Irated: 350 / 400 / 500 / 550mA, Prated: 75.6 / 74.8 / 75.0 / 74.8W,

Urated: (90 - 216) / (90 - 187) / (90 - 150) / (90 - 136) Vdc.

Columnal

8 September 2021

Electrical & Gas Approvals, NSW Fair Trading, PO Box 972, Parramatta NSW 2124 02 9895 0722

Email: energyapprovals@customerservice.nsw.gov.au

Website: www.fairtrading.nsw.gov.au





This certificate will expire on 14/06/2023

Approved pursuant to Clause 15 (1) of the Gas and Electricity (Consumer Safety) Regulation 2018:

8 September 2021

For Secretary, Department of Customer Service

Ilm al

Email: energyapprovals@customerservice.nsw.gov.au

Website: www.fairtrading.nsw.gov.au