



Dear Sir/Madam

MODIFICATION TO CERTIFICATE OF APPROVAL: NSW28523

Power Supply or Charger

Please find enclosed an addendum to the certificate as sought in your application.

Yours faithfully,

Glenn Tuck

For Secretary, Department of Customer Service

Electrical & Gas Approvals
PO Box 972, Parramatta NSW 2124
02 9372 8312

Email: energyapprovals@customerservice.nsw.gov.au
Website: www.fairtrading.nsw.gov.au

ADDENDUM TO CERTIFICATE OF APPROVAL: NSW28523

Particulars of Modification(s)

Model No. IT FIT 14/220-240/350 CS TI-x being similar to original article IT FIT 15/220-240/700 CS I, except Current selected.

- 1) Irated: 200mA, Prated: 8W, Urated: 30-40Vdc, In: 50mA, Ta: -20°C to +35°C, Tc: 65°C.
 - 2) Irated: 250mA, Prated: 10W, Urated: 30-40Vdc, In: 55mA, Ta: -20°C to +35°C, Tc: 65°C.
 - 3) Irated: 300mA, Prated: 12W, Urated: 30-40Vdc, In: 65mA, Ta: -20°C to +35°C, Tc: 65°C
 - 4) Irated: 350mA, Prated: 14W, Urated: 30-40Vdc, In: 75mA, Ta: -20°C to +35°C, Tc: 65°C
- (x can be B,W or G, which indicates the enclosure colour can be black, white or grey.)

Model No. IT FIT 22/220-240/550 CS TI-x being similar to original article IT FIT 15/220-240/700 CS I, except Current selected.

- 1) Irated: 400mA, Prated: 16W, Urated: 30-40Vdc, In: 95mA, Ta: -20°C to +35°C, Tc: 65°C.
 - 2) Irated: 450mA, Prated: 18W, Urated: 30-40Vdc, In: 105mA, Ta: -20°C to +35°C, Tc: 65°C.
 - 3) Irated: 500mA, Prated: 20W, Urated: 30-40Vdc, In: 115mA, Ta: -20°C to +35°C, Tc: 65°C.
 - 4) Irated: 550mA, Prated: 22W, Urated: 30-40Vdc, In: 125mA, Ta: -20°C to +35°C, Tc: 65°C.
- (x can be B,W or G, which indicates the enclosure colour can be black, white or grey.)

Model No. IT FIT 30/220-240/900 CS TI-x being similar to original article IT FIT 15/220-240/700 CS I, except Current selected.

- 1) Irated: 600mA, Prated: 24W, Urated: 30-40Vdc, In: 130mA, Ta: -20°C to +35°C, Tc: 65°C.
 - 2) Irated: 650mA, Prated: 26W, Urated: 30-40Vdc, In: 135mA, Ta: -20°C to +35°C, Tc: 65°C.
 - 3) Irated: 700mA, Prated: 28W, Urated: 30-40Vdc, In: 145mA, Ta: -20°C to +35°C, Tc: 65°C.
 - 4) Irated: 750mA, Prated: 30W, Urated: 30-40Vdc, In: 155mA, Ta: -20°C to +35°C, Tc: 65°C.
- (x can be B,W or G, which indicates the enclosure colour can be black, white or grey.)

This certificate will expire on 11/05/2026

Approved pursuant to Clause 15 (1) of the Gas and Electricity (Consumer Safety) Regulation 2018:



For Secretary, Department of Customer Service