



File Ref: NSW28035/19  
Contact: Admin Clerk  
Telephone: 02 9372 8312

Darren Miruzzi  
Inventronics (Hong Kong) Limited  
Room 1903, 19/F, Lee Garden One  
33 Hysan Avenue, Causeway Bay  
Hong Kong

Dear Sir/Madam

MODIFICATION TO CERTIFICATE OF APPROVAL: NSW28035

Power Supply or Charger

Please find enclosed an addendum to the certificate as sought in your application.

Yours faithfully,

For Secretary, Department of Customer Service

## **ADDENDUM TO CERTIFICATE OF APPROVAL: NSW28035**

### **Particulars of Modification(s)**

IT DALI 42/220-240/1050 CS HE being similar to original article OTi DALI 50/220-240/1A4 LT2 FAN NFC, except Current selected by dip switch:

Option 1: Irated: 600mA, Prated: 25.2W, Urated: 30-42Vdc, In: 0.130A, Ta: -20 to +50°C.  
Option 2: Irated: 700mA, Prated: 29.4W, Urated: 30-42Vdc, In: 0.157A, Ta: -20 to +50°C.  
Option 3: Irated: 750mA, Prated: 31.5W, Urated: 30-42Vdc, In: 0.167A, Ta: -20 to +50°C.  
Option 4: Irated: 800mA, Prated: 33.6W, Urated: 30-42Vdc, In: 0.178A, Ta: -20 to +50°C.  
Option 5: Irated: 850mA, Prated: 35.7W, Urated: 30-42Vdc, In: 0.189A, Ta: -20 to +50°C.  
Option 6: Irated: 900mA, Prated: 37.8W, Urated: 30-42Vdc, In: 0.199A, Ta: -20 to +45°C.  
Option 7: Irated: 950mA, Prated: 39.9W, Urated: 30-42Vdc, In: 0.210A, Ta: -20 to +45°C.  
Option 8: Irated: 1050mA, Prated: 42.0W, Urated: 30-40Vdc, In: 0.220A, Ta: -20 to +45°C.

This certificate will expire on 11/09/2028

Approved pursuant to Clause 15 (1) of the Gas and Electricity (Consumer Safety) Regulation 2018:



For Secretary, Department of Customer Service