



File Ref: NSW29571/3
Contact: Admin Clerk
Telephone: 02 9372 8312

Darren Miruzzi
Inventronics (Hong Kong) Limited
Room 1903, 19/F, Lee Garden One
33 Hysan Avenue
Causeway Bay, Hong Kong

Dear Sir/Madam

MODIFICATION TO CERTIFICATE OF APPROVAL: NSW29571

Power Supply or Charger

Please find enclosed an addendum to the certificate as sought in your application.

Yours faithfully,

For Secretary, Department of Customer Service

ADDENDUM TO CERTIFICATE OF APPROVAL: NSW29571 Particulars of Modification(s)

Addition of the following track-mount built-in LED drivers with IEC 60570 compliant track adaptor, reprogrammable constant current type SELV output, housed in thermoplastic enclosure, 220-240Vac, 50/60Hz, Fmax =50N (ceiling installation) or 25N (horizontal installation) –

- 1) Model IT FIT 14/220-240/350 CS T-x HE, Irated 200-350mA, Prated 8-14W, Urated 30-40Vdc, In 50-80mA, Ta -20 Degree C to 35 Degree C, Tc 65 Degree C;
- 2) Model IT FIT 22/220-240/550 CS T-x HE, Irated 400-550mA, Prated 16-22W, Urated 30-40Vdc, In 95-125mA, Ta -20 Degree C to 35 Degree C, Tc 65 Degree C;
- 3) Model IT FIT 30/220-240/750 CS T-x HE, Irated 600-750mA, Prated 24-30W, Urated 30-40Vdc, In 140-170mA, Ta -20 Degree C to 35 Degree C, Tc 65 Degree C;
- 4) Model IT FIT 42/220-240/1A0 CS T-x HE, Irated 800-1050mA, Prated 32-42W, Urated 30-40Vdc, In 185-240mA, Ta -20 Degree C to 35 Degree C, Tc 65 Degree C.

Where 'x' in model designation may be letter B, W, or G representing body finish colour in black, white, or grey.

This certificate will expire on 21/07/2030

Approved pursuant to Clause 15 (1) of the Gas and Electricity (Consumer Safety) Regulation 2018:



For Secretary, Department of Customer Service